

# Boston

April 4, 2012

Mr. Hank Voorvaart  
The City Master Box Div  
Alarm Applications, Inc.  
PO Box 297  
Colchester CT 06415

After review and bench testing for compatibility with the Boston Fire Department's municipal alarm system, Commissioner Roderick Fraser has authorized the use of Alarm Applications "Master Box" for use for indoor applications. This approval covers the transmission of the fire box number to Fire Alarm only. BFD Fire Alarm does not provide monitoring of trouble or supervisory conditions nor does this approval allow for this to occur with the electronic boxes

The Boston Fire Department does not endorse individual products or devices. This approval authorizes the use of the "Master Box" product to connect to the City of Boston municipal alarm system only. The approval is solely for this device. Any other products you or competitors wish to submit in the future will require individual review and approval for each product.


Sincerely,



Deputy Chief /Fire Marshal  
Fire Prevention Division  
Boston Fire Department  
1010 Mass Ave. Boston Ma. 02118



Thomas M. Menino, Mayor/FIRE DEPARTMENT/115 Southampton Street 02118

 Printed on recycled paper

 31